

CERTIFICATE

Certificate holder	Gamrat Spółka Akcyjna ul. Mickiewicza 108 38-200 Jasło POLAND
Production facility	Jasło
Product	Pressure pipes made from Polyethylene (PE) for alternative installation techniques - PE 100-RC
Classification	EG 926.3, Outer Diameter 250 mm up to 630 mm
Type, Model	TWINGAM PE100RC/PE100RC
Remarks to the type	PAS 1075 Type 2 - G Basis EN 1555-2
Testing basis	PAS 1075:2009-04 Certification Scheme Plastic Piping Systems (Pressure Pipes and Fittings) (2017-05)

Mark of conformity



Registration No. P1R0482

Valid until 2026-10-31

Right of use

This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number.
See annex for further information.

2021-08-10

Dipl.-Wi.-Ing. (FH) Sören Scholz
Head of Certification Body

S. Scholz



ANNEX

Page 1 of 1

Certificate

P1R0482 dated 2021-08-10

Technical Data

PAS 1075 Type 2 - G
Basis PN EN 1555-2

Outer diameter: 250 mm up to 630 mm

Material: PE 100-RC

Type: see production facility related material list

Colour outer layer: orange
Colour inner layer: black

Operating over pressure burstlining: see Certification Scheme Plastic piping systems
(Pressure pipes and fittings)(2017-05) Annex O 14

**Testing laboratory/
Inspection body**

Hessel Ingenieurtechnik GmbH
Am Münsterwald 3
52159 Roetgen
GERMANY

Test report(s)

R16 02 3074_ACT dated 2016-10-07
R16 02 3074_A_PLT+ dated 2016-10-07
R20 03 3938-D_ACT dated 2020-11-23

