



CERTIFICATE

Certificate holder	Gamrat Spółka Akcyjna ul. Mickiewicza 108 38-200 Jasło POLAND
Production facility	Jasło
Product	Pressure pipes made from Polyethylene (PE) for alternative installation techniques - PE 100-RC
Classification	EG 926.1, Outer Diameter 20 mm up to 63 mm
Type, Model	TWINGAM PE100RC
Remarks to the type	PAS 1075 Type 1 - G PN EN 1555-2
Testing basis	PAS 1075:2009-04 Certification Scheme Plastic Piping Systems (Pressure Pipes and Fittings) (2017-05)
Mark of conformity	
Registration No.	P1R0473
Valid until	2026-09-30
Right of use	This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number. See annex for further information.

2021-08-10


Dipl.-Wi.-Ing. (FH) Sören Scholz
Head of Certification Body



ANNEX

Page 1 of 1

Certificate

P1R0473 dated 2021-08-10

Technical Data

PAS 1075 Type 1 - G
Basis PN EN 1555-2

Outer diameter: 20 mm up to 63 mm
Minimum wall thickness: 3,0 mm

Material: PE 100-RC

Type: see production facility related material list

Colour: orange-yellow

Operating over pressure burstlining: see Certification Scheme Plastic piping systems
(Pressure pipes and fittings)(2017-05) Annex O 14

**Testing laboratory/
Inspection body**

Hessel Ingenieurtechnik GmbH
Am Münsterwald 3
52159 Roetgen
GERMANY

Test report(s)

R16 01 3023-A2_(PLT+) dated 2016-07-23
R17 01 3292-G1_(PLT+) dated 2017-19-12
R20 03 3938-A_PLT+ dated 2020-11-20

