

NATIONAL DECLARATION OF PERFORMANCE

No. 35/ZR/23

1. Name and trade name of the construction product:

**Segmented fittings of polyethylene pipes for water, domestic water supply and sewerage
DN 90-500**

2. Designation of construction product type:

- Bends: SDR 11; SDR 13.6; SDR 17; SDR 21; SDR 26 with angles of 1°÷90° - PE 100**
- Tees: SDR 11; SDR 13.6; SDR 17; SDR 21; SDR 26 – PE 100**
- Reducing tees: SDR 11; SDR 13.6; SDR 17; SDR 21; SDR 26 – PE 100**
- Reducers: SDR 11; SDR 13.6; SDR 17; SDR 21; SDR 26 – PE 100**

3. Intended use(s):

Segmented fittings fabricated out of polyethylene pipes of the PE 100 class are used for the supply of water intended for human consumption, including the supply of water prior to its treatment, for the pressure supply of domestic water and rainwater, as well as for the pressure and vacuum transport of sewage water and for the supply of water for other purposes.

4. Manufacturer's name and registered office address and place of production:

Gamrat SA, 38-200 Jasło, ul. Mickiewicza 108, Jasło Plant

5. Authorized representative's name and registered office address, if any:

not applicable

6. The national system used to assess and verify the constancy of performance:

"System-4"

7. National technical specification:

7a. Polish Standard for the product:

PN-EN 12201-3+A1:2013 "Plastics piping systems for water supply, and for drainage and sewerage under pressure – Polyethylene (PE) – Part 3: Fittings"

Name of the accredited certification body, accreditation number and national certificate number or the name of the accredited laboratory/laboratories and accreditation number:

not applicable

7b. National Technical Assessment:

not applicable

Technical assessment unit/National technical assessment unit:

not applicable

Name of the accredited certification body, accreditation number and certificate number:

not applicable

8. Declared performance:

<i>Essential characteristics of the construction product for the intended use or uses</i>	<i>Declared performance</i>	<i>Notes</i>
Material properties	Pipes for the fabrication of segmented fittings are in accordance with EN 12201-2+A1:2013, Annex B, Clause B.1	Pressure correction factors: Bends – 1.0 Tees – 0.8
Appearance and colour	In accordance with PN-EN 12201-3+A1:2013, Clauses 5.1, 5.2 Annex B, Clause B.1	
Dimensions	In accordance with PN-EN 12201-3+A1:2013, Clauses 5.1, 5.2 Annex B, Clause B.2	
Effect on water quality	In accordance with PN-EN 12201-3+A1:2013, Clause 5.6	It has been granted a hygienic approval. No. B.BK.60110.1190.2022, which is valid until 2025-10-10.
Mechanical characteristics	Hydrostatic strength in accordance with PN-EN 12201-3+A1:2013, Annex B – Table B.1 20°C, 100 h 80°C, 1000 h	
	Tensile strength for fabricated fittings PN-EN 12201-3+A1:2013, Annex B – Table B.1	
Fitness	Fitness for purpose for butt fusion joint in accordance with PN-EN 12201-3+A1:2013, Clause 10 and PN-EN 12201-5:2012, Clause 4.2.2	
Marking	In accordance with PN-EN 12201-3+A1:2013, Clause 11 Annex B, Clause B.1	

9. The performance of the product identified above is in conformity with all declared performance characteristics listed in Section 8. This National Declaration of Performance is issued in accordance with the Act on Construction Products of April 16, 2004, under the sole responsibility of the manufacturer.

Signed for and on behalf of the manufacturer by:

Jerzy Pachana – Board Member, General Director
(name and position)

Członek Zarządu
Dyrektor Generalny

Jerzy Pachana

(signature)

Jasło, 09.01.2023
(place and date of issue)

Form: Q 026 - Issue 2-11/19